



REDBOOK:
Customer Engineering Standards
And Metering Requirements

July 2025

CUSTOMER ENGINEERING AND METERING REQUIREMENTS INDEX

For more information or if you have questions on these requirements please contact our Benton PUD Engineering Department at 509-582-1230

General Information

Q-1A	Meter Socket Terminal Clip Configuration
Q-1B	Residential & Commercial Services Maximum Wire Lengths and Required Conduit Sizes
Q-1C	Multiple Meter Base Identification Numbering Requirements for Multi-Unit Mobile Home Parks & Multi-Unit Buildings
Q-1D	Group Meter Base Installation for Apartments, Strip Malls etc.
Q-1E	2-1/2" x 3" Conduit Adapter for 200Amp Meter Base
Q-1F	Minimum Clearance Requirements for Self-Contained Meter Installations

Temporary Services

Q-2A	Metered or Un-Metered Temporary Service Requirements Overhead Feed
Q-2B	Metered or Un-Metered Temporary Service Requirements Underground Area
Q-2C	Alternate Temporary Service Installation Guidelines

Overhead Services

Q-3A	New and/or Altered Through Roof Mast Installation 200Amp or Less
Q-3B	New and/or Altered Below Roof Mast Installation 200Amp or Less
Q-3C	Overhead Feed Single Phase Meter Base 200Amp, 240/480 Volt 3-Wire
Q-3D	Overhead Feed 200Amp or Less Meter Base, Single Phase, 120/240 Volt, Residential
Q-3E	Overhead Feed 200Amp or Less Meter Base, Network, 120/208 Volt, Residential
Q-3F	Overhead Feed 200Amp Meter Base, Single Phase, 120/240 Volt, Non-Residential
Q-3G	Overhead Feed 200Amp Meter Base, Network, 120/208 Volt, Non-Residential
Q-3H	Overhead Feed 320Amp Meter Base, Single Phase, 120/240 Volt
Q-3J	Overhead Feed 200Amp Meter Base, Three Phase, 600 Volt, Non-Residential

Underground Services

Q-4A	Service Entrance Surface Mounted -Underground 400Amp or Less
Q-4B	Service Entrance Flush Mounted -Underground 400Amp or Less
Q-4C	Underground Feed 200Amp Meter Base Single Phase 120/240 Volt, Residential
Q-4D	Underground Feed 200Amp Meter Base, Network, 120/208 Volt, Residential
Q-4E	Underground Feed 200Amp Meter Base, Single Phase, 120/240 Volt, Non-Residential
Q-4F	Underground Feed 200Amp Meter Base, Network, 120/208 Volt, Non-Residential
Q-4G	Underground Feed 320Amp Meter Base, Single Phase, 120/240 Volt, Residential or Commercial
Q-4H	Underground Feed 200Amp Meter Base, Three Phase, 600 Volt, Non-Residential
Q-4J	Underground Service 200Amp for Metered Pedestal
Q-4K	200Amp Component Meter Pedestal (Mounted on Uni-Strut)
Q-4L	320Amp Component Meter Pedestal (Mounted on Uni-Strut)
Q-4M	Pre-Approved Meter Bases

Current Transformers

Q-5A	Current Transformer Enclosure (Mounted on Uni-Strut)
Q-5B	Current Transformer (CT) Compartment Requirements for Residential Services 201-800 Amps, (2 Pages)
Q-5E	Current Transformer (CT) Compartment Requirements for Commercial Three Phase Services 201-800 Amps (2 Pages)
Q-5F	Current Transformer (CT) Compartment Requirements for Commercial Three Phase Services 1200-2500 Amps (2 Pages)
Q-5G	Self Supported CT Meter Pedestal with CT's installed in Secondary Side of District Transformer
Q-5H	Current Transformer Compartment for Switch gear 1000-3000 Amp

Transformer Pads and Clearances

Q-6C	Installation Clearances for Commercial and Residential Transformers
Q-6G	600V Termination Cabinet Guideline
UG6-C	Transformer Pad Details 500 kVA and Below Three Phase (2 Pages)
UG6-C2	Transformer Pad Details 750 kVA and Above Three Phase (2 Pages)
UG6-C3	Pre-Cast Transformer Pad 500 kVA and Below Three Phase (2 Pages)

Trenching

- | | |
|-------------|--|
| Q-7A | Trenching and Conduit Details for Typical Underground Service Installation, from Pad Mount Transformer |
| Q-7B | Trenching and Conduit Details for Typical Underground Service Installation, from Overhead |

Net Metering Services

- | | |
|-------------|---|
| Q-8A | Net Metering Typical One Line Schematic (No Battery Backup) |
| Q-8B | Net Metering Typical One Line Schematic (Battery Backup) |

Fiber Services

- | | |
|-------------|--|
| Q-9A | Installation Practices for Customer Fiber Services |
|-------------|--|

Work Area Clearances

- | | |
|--------------|--|
| Q-10A | Work Area Clearance (Utility Poles & Junction Boxes) |
| Q-10B | Work Area Clearance (Pedestals) |

GENERAL INFORMATION

5/19/2025 2:37 PM F:\Apps\Eng\Engineering Drawings\Construction Standards Drawings\Construction Standards Folders Copyright © 2025 Public Utility District No. 1 of Benton County



TITLE:


GENERAL INFORMATION
Q-1 Series

REV BY: MM	SHT.
REV DATE: 05/19/25	1 of 1
REV NO: 2	DATE:
DIR. ENG.	
DWG. NO.	
Q-1	

DRAWN BY: JAD

DRAW DATE: 03/05/04

		Self Contained Meter Base (Furnished and provided by customer)			Current Transformer Meter Base (Provided by District)		
Voltage	Wires	Max Amp.	No. Clips	Socket	No. CT.	No. Clips	Socket
Single Phase							
120/240	3	200 Res / Comm'l	4	A	2	6	C/Test SW
120/240	3	320 Res / Comm'l	4	A			
240/480	3	200	4	A			
Network							
120/208	3	200	5	B			
Three Phase							
208/120	4	200	7	D	3	13	E/Test SW
240/120	4	200	7	D	3	13	E/Test SW
240/480	4	200	7	D	3	13	E/Test SW
480/277	4	200	7	D	3	13	E/Test SW

**Notes:**

1. Manual block by pass required on all 200 Amp non-residential installations, and all 320 Amp installations.
2. No automatic, plunger, or lever type by pass devices allowed.
3. Meters are required to be mounted external to the building. Exceptions will need to be approved by District Engineering and Metering Departments prior to construction.
4. Sockets A,B,D, will be provided by the customer.
5. Sockets C & E will be provided by the District for the customer to install.
6. The meter base for single phase, two wire service, shall be the same as a single phase, three wire service, with the upper right terminal tied to the neutral. Three phase, three wire service shall be metered as a three phase four wire service.
7. Socket B will have the 9 o'clock terminal position tied to the neutral.
8. Ringless meter bases will not be approved by the District.
9. The addition of customer owned equipment between the socket and utility owned electric meter, such as an intermediate internal transfer switch, is not allowed.



TITLE:

Meter Socket Terminal Clip Configuration

DRAWN BY: JAD

DRAW DATE: 02/16/01

REV BY: TMG

SHT.

REV DATE: 9/14/2020

1 of 1

REV No: 1

DIR.

ENG

DATE:

9/22/20

DWG. NO.

Q-1A

Service and Conduit Requirements

Residential UG Services	Meter Base Type	Minimum Conduit Size, Type	Maximum Service Conductor Length
200A 400A, (320A Class) 400A - 600A 800A and Over	Self Contained Self Contained CT Meter CT Meter	3" Sch 40 3" Sch 40 4" Sch 40 See Note 6	200FT * 250FT * 250FT * See Note 6

Service Requirements

Commercial UG Services	Meter Base Type
200A, 1Ø 400A, 1Ø (320A Class) 400A, 1Ø Over 400A, 1Ø 200A, 3Ø Over 200A, 3Ø	Self Contained Self Contained CT Meter CT Meter Self Contained CT Meter

* Distances are based on measurements from the padmount transformer, remember to account for the extra 50 feet for pole mount transformer installations.

Notes:

- Details shown are minimum District standards and are not intended to depict the Washington State Labor and Industries requirements.
- Conduit may not exceed maximum allowable length, or have bends exceeding 270 degrees including sweeps at the meter base and transformer or pole.
- Customer owned and installed service wires for single phase services are limited to (4) sets of conductors and shall not exceed 500 kcmil aluminum or copper.
- Customer owned and installed service wires for three phase services are limited to (6) sets of conductors and shall not exceed 750 kcmil aluminum or copper.
- Commercial underground service entrance conductor is considered to be customer owned and installed for both self-contained and instrument rated metering (CT metering) regardless of the meter location (i.e. transformer, CT cabinet, or other self-contained unit), and is subject to the requirements of currently adopted National Electrical Code and Washington Administrative Code for size (ampereage requirement) and voltage drop.
- Residential services 800A and above will be customer owned and installed service conductor.
- The District will supply conductor for overhead services up to 400A, if adequate support structures are available and service length does not exceed calculated limits.




TITLE:

Residential & Commercial Services Maximum Lengths & Required Conduit Sizes


REV BY: MM	SHT: 1 of 1
REV DATE: 5/1/2025	
REV NO: 4	DIR: <i>JA</i> DATE: 5/19/25
DWG. NO.	
Q-1B	

DRAWN BY: SWT

DRAW DATE: 02/26/01



Manufactured Home Type



**Apartment / Multi-Family
Buildings**

Notes:

- 1.) Before permanent service is connected raised letters and numbers (1" min. height) or *engraved* placard as approved by the District must be permanently attached to the meter base, apartment door and apartment panel. No adhesive non-raised letters or numbers allowed.




DRAWN BY: SWT
DRAW DATE: 03/27/01

TITLE:

Multiple Meter Base Identification
Numbering Requirements for
Multi- Unit Mobile Home Parks
& Multi Unit Buildings

REV BY: JWV	SHT. 1 of 1
REV DATE: 10/01/13	
REV No: 1	DIR. ENG. <i>[Signature]</i> DATE: <i>1/1</i>
DWG. NO.	

Q-1C



Side Of Building

**Acceptable
Installation**

Notes:

1. Details shown are minimum District specifications and are not intended to depict Washington State Labor and Industries requirements.
2. Permanent service will not be connected without proper meter base identification, refer to Q-1C for meter base identification requirements.
3. Access to supply conductors must be capable of being sealed by the District.
4. District approval must be obtained in writing for any of the following:
 - A. If any disconnect is installed on the delivery side of meters.
 - B. If meter installation is over 4' from the front, on the side of the building.
 - C. If other than outside installation.
5. All multi-pack meter bases must be pre-approved by District Engineers.
6. All service Conductor is to be furnished and installed by the customer.




DRAWN BY: SWT
DRAW DATE: 02/25/01

TITLE:

**Multi-Tenant Meter Base Installation
For Apartments, Strip Malls, etc.**

REV BY: TMG	SHT.
REV DATE: 9/14/2020	1 of 1
REV NO: 2	DIR. ENG. <i>[Signature]</i> DATE: 9/21/20
DWG. NO.	Q-1D

District conductor
to bottom of meter
base on left side



Notes:

1. Reducer (supplied by customer) 3" x 2-1/2" x 8" shall not have sharp internal edges.
2. Carlon adapters are supplied by customer and must be pre-approved to meet District requirements.




DRAWN BY: SWT
DRAW DATE: 12/20/00

TITLE:

2 1/2" x 3" Conduit Adapter
for 200 Amp Meter Base

REV BY: JWV	SHT.
REV DATE: 10/01/13	1 of 1
REV No: 1	DIR. <i>JD</i> DATE: 1/14
DWG. NO.	

Q-1E

**Notes:**

- Details shown are minimum District specifications and are not intended to depict Washington State Labor and Industries requirements.
- Clearance space will be measured from the front of meter enclosure.
- 250V or less requires 36\" total minimum clearance.
- Over 250V requires 48\" total minimum clearance.
- Minimum clearance of 36\" from meter base to door and window openings.
- Minimum clearance of 9\" above meter must be maintained free of obstructions.
- Minimum clearance of 36\" from gas meter.
- Meter base must be located within 48\" of the front of the building.
- Minimum clearance requirements will be from property line or any obstructions.



TITLE:

Minimum Clearance Requirements For Self Contained Meter Installations

DRAWN BY: JAD

DRAW DATE: 03/27/11

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/29/2020	
REV No: 2	DIR. ENG. <i>[Signature]</i> DATE: 9/21/20
DWG. NO.	

Q-1F

TEMPORARY SERVICE

5/19/2025 2:36 PM F:\Apps\Eng\Engineering Drawings\Construction Standards Drawings\Construction Standards Folders Copyright © 2025 Public Utility District No. 1 of Benton County




DRAWN BY: JAD

DRAW DATE: 03/05/04

TITLE:

TEMPORARY SERVICE
Q-2 Series

REV BY: MM	SHT.
REV DATE: 05/19/25	1 of 1
REV NO: 2	DATE:
DIR. ENG.	
DWG. NO.	
Q-2	



Notes:

1. Details shown are minimum District specifications and are not intended to depict Washington State Labor and Industries requirements.
2. Applications for temporary service are required in advance of the service being requested.
3. All temporary power installations will be metered and will not exceed one year.
4. Customer's temporary service pole may be of 4" x 4" solid lumber or two 2" x 4" lumber laminated together.
5. Braces will consist of 2" x 4" lumber with stakes solidly driven into the ground and firmly attached to braces.
6. All clearances must meet or exceed the National Electrical Safety Code.
7. Contact 811 to request utility locates two days prior to digging.




TITLE:

Temporary Service Requirements Overhead Services

DRAWN BY: JAD
DRAW DATE: 3/28/01

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/29/2020	
REV No: 2	DATE: 9/21/20
DWG. NO.	




Q-2A



Notes:

1. Details shown are minimum District specifications and are not intended to depict Washington State Labor and Industries requirements.
2. Applications for temporary service are required in advance of the service being requested.
3. All temporary power installations will be metered and will not exceed one year.
4. Customer's shall provide all trenching, backfill and sufficient conductor plus 6' to reach District facilities.
5. Permanent service stub-outs may not be utilized for temporary power conductor.
6. Customer's temporary service pole may be of 4" x 4" solid lumber or two 2" x 4" lumber laminated together.
7. Braces will consist of 2" x 4" lumber with stakes solidly driven into the ground and firmly attached to braces.
8. All clearances must meet or exceed the National Electrical Safety Code.
9. Contact 811 to request utility locates two days prior to digging.

TITLE:



Notes:

1. The District shall determine if hand hole is required for conductor installation.
2. Customer will install District supplied or other pre-approved hand hole to grade as well as necessary sweeps and conduit prior to temporary or permanent service inspections.

BENTON
PUD

DRAWN BY: JWW

DRAW DATE: 10/01/13

TITLE:

**Alternate Temporary Services
Installation Guidelines**


REV BY: TMG	SHT. 1 of 1
REV DATE: 8/29/2020	
REV No: 1	DATE: 9/21/20
DWG. NO.	

Q-2C

OVERHEAD SERVICE

5/19/2025 3:01 PM F:\Apps\Eng\Engineering Drawings\Construction Standards Drawings\Construction Standards Folders Copyright © 2025 Public Utility District No. 1 of Benton County

	TITLE: OVERHEAD SERVICES Q-3 Series	REV BY: MM		SHT. 1 of 1
		REV DATE: 05/19/25		
		REV NO: 2	DIR. ENG.	DATE:
		DWG. NO. Q-3		
DRAWN BY: JAD				
DRAW DATE: 03/05/04				

**Notes:**

- Details shown are minimum District specifications and are not intended to depict Washington State Labor and Industries requirements. Ref. WAC 296-46B-230-028.
- Service drops must maintain minimum ground line clearance requirements at lowest point per the National Electrical Safety Code, Rule 232.



TITLE:

New and/or Altered Service Through Roof 200 Amp or Less

DRAWN BY: JAD

DRAW DATE: 02/28/01

REV BY: MM

REV DATE: 5/5/2025

SHT.

1 of 1

REV NO: 4


DIR. ENG.

DATE:


5/12/25

DWG. NO.


Q-3A



View A-A




View B-B



Elevation

Guy Attached To Eye bolt



Elevation

Guy Attached To Rigid Conduit

Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Service drops must maintain minimum ground line clearance requirements at lowest point per the National Electrical Safety Code, Rule 232.



TITLE:



**New and/or Altered Service
Below Roof Mast Installation
200 Amp or Less**

DRAWN BY: JAD

DRAW DATE: 03/27/11

REV BY: TMG	SHT.
REV DATE: 8/19/2020	1 of 1
REV No: 2	DIR. ENG. DATE: 7/21/20
DWG. NO.	

Q-3B

**Top View****Front View**

Customer to furnish
and install conduit
per the NEC

Service entrance
conductors furnished
and installed by customer
per the NEC

Note 4

Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Customer shall contact Customer Engineering prior to installation.
3. The customer shall supply mast, service entrance conductors and meter base.
4. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
5. Ringless meter bases will not be approved by the District.
6. No conduit type fittings to be installed in conduit containing service conductors.
7. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.



DRAWN BY: JAD

DRAW DATE: 02/26/01

TITLE:

**Overhead Feed
Single Phase Meter Base
200 Amp, 240/480 Volt 3 Wire
Non-Typical**

REV BY: TMG

REV DATE: 8/29/2020

REV No: 3

DIR. ENG. *[Signature]*


SHT.

1 of 1

DATE: 9/21/20

DWG. NO.

Q-3C



Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Customer shall contact Customer Engineering prior to installation.
3. The customer shall supply mast, service entrance conductors and meter base.
4. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
5. For pre-approved meter bases, see document **Standard Q-4M**.
6. Ringless meter bases will not be approved by the District.
7. No conduit type fittings to be installed in conduit containing service conductors.
8. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.




DRAWN BY: JAD
DRAW DATE: 02/26/01

TITLE:

Overhead Feed
200 Amp or Less Meter Base
Single Phase, 120/240 Volt
Residential

REV BY: TMG	SHT.
REV DATE: 8/19/2020	1 of 1
REV No: 3	DIR. ENG. <i>[Signature]</i> DATE: 7/21/20
DWG. NO.	Q-3D



Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Customer shall contact Customer Engineering prior to installation.
3. The customer shall supply mast, service entrance conductors and meter base.
4. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
5. For pre-approved meter bases, see document **Standard Q-4M**.
6. Ringless meter bases will not be approved by the District.
7. No conduit type fittings to be installed in conduit containing service conductors.
8. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.




DRAWN BY: JAD
DRAW DATE: 02/16/01

TITLE:

Overhead Feed
200 Amp or Less Meter Base
Network 120/208 Volt
Residential

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/19/2020	
REV NO: 2	DIR. ENG. <i>Set</i> DATE: 7/21/20
DWG. NO.	Q-3E



Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Customer shall contact Customer Engineering prior to installation.
3. The customer shall supply mast, service entrance conductors and meter base.
4. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
5. For pre-approved meter bases, see document **Standard Q-4M**.
6. Ringless meter bases and safety socket by-passes will not be approved by the District.
7. No conduit type fittings to be installed in conduit containing service conductors.
8. Manual block type by-pass is required for 200A non-residential services.
7. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.




DRAWN BY: JAD
DRAW DATE: 02/26/01

TITLE:

Overhead Feed
200 Amp Meter Base
Single Phase 120/240 Volt
Non-Residential

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/19/2020	
REV NO: 2	DIR. ENG. DATE: 9/21/20
DWG. NO.	
Q-3F	



Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Customer shall contact Customer Engineering prior to installation.
3. The customer shall supply mast, service entrance conductors and meter base.
4. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
5. For pre-approved meter bases, see document **Standard Q-4M**.
6. Ringless meter bases and safety socket by-passes will not be approved by the District.
7. No conduit type fittings to be installed in conduit containing service conductors.
8. Manual block type by-pass is required for 200A non-residential services.
9. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.




DRAWN BY: JAD
DRAW DATE: 02/26/01

TITLE:

Overhead Feed
200 Amp Meter Base
Network 120/208 Volt
Non-Residential

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/19/2020	
REV NO: 2	DIR. ENG. <i>[Signature]</i> DATE: 9/21/20
DWG. NO.	

Q-3G

**Notes:****Front View**

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Customer shall contact Customer Engineering prior to installation.
3. The customer shall supply mast, service entrance conductors and meter base.
4. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
5. For pre-approved meter bases, see document **Standard Q-4M**.
6. Ringless meter bases, and safety socket and lever by-passes will not be approved by the District.
7. All self-contained 320A services must use meter sockets rated for 320A continuous duty.
8. No conduit type fittings to be installed in conduit containing service conductors.
9. Manual block type by-pass is required for 320A services.
10. Doubling of wires is allowed with factory provided, UL approved connectors, only when conductor type and size are the same.




DRAWN BY: JAD
DRAW DATE: 03/27/01

TITLE:

Overhead Feed
320 Amp Meter Base
Single Phase, 120/240 Volt
Residential and Commerical

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/19/2020	
REV NO: 2	DIR. ENG. <i>[Signature]</i> DATE: 9/21/20
DWG. NO.	Q-3H



Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Customer shall contact Customer Engineering prior to installation.
3. The customer shall supply mast, service entrance conductors and meter base.
4. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
5. For pre-approved meter bases, see document **Standard Q-4M**.
6. Ringless meter bases and safety socket by-passes will not be approved by the District.
7. No conduit type fittings to be installed in conduit containing service conductors.
8. Manual block type by-pass is required for 200A non-residential services.
9. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.
10. Power conductor (high leg, color coded orange).



TITLE:

Overhead Feed
200 Amp Meter Base
Three Phase
Non-Residential

DRAWN BY: JAD

DRAW DATE: 02/26/01

REV BY: TMG

REV DATE: 8/19/2020

REV NO: 2

DIR.
ENG. *etj*

SHT.

1 of 1

DATE: 9/21/20

DWG. NO.

Q-3J

UNDERGROUND SERVICES




DRAWN BY: JAD
DRAW DATE: 03/05/04

TITLE:

UNDERGROUND SERVICES
Q-4 Series

REV BY: MM	SHT.
REV DATE: 05/19/25	1 of 1
REV NO: 2	DATE:
DIR. ENG.	
DWG. NO.	
Q-4	

Provided And Installed By Customer	
Item No.	Description
③	Meter Base
④	3" Rigid PVC Conduit
⑤	Sweep 3" sch. 40 PVC 36" radius
⑥	Conduit-3" Sch. 40 PVC
⑦	3" to 2-1/2" adapter for 200A meter base only refer to Q-1E standard
⑧	Conduit Straps
Provided And Installed By District	
Item No.	Description
①	Conductors
②	Meter



Notes:

- Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
- The District's service conductors will connect at the meter socket line terminals.
- Meter base must be installed, plumb and solid, and bonded to customer neutral per NEC, as required.
- For pre-approved meter bases and details, ref. District standards Q4-C through Q-4M.
- Reference District standards Q-7A and Q-7B for trenching details.
- 320A meter bases may only be utilized for single phase installations.
- Ringless meter bases will not be approved by the District.
- No conduit type fittings to be installed in conduit containing service conductors.



DRAWN BY: JAD
DRAW DATE: 03/22/01


TITLE:

Service Entrance
Surface Mounted Underground
400 Amp or Less

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/19/2020	
REV NO: 3	DIR. ENG. 8/19/20
DWG. NO.	

Q-4A

Provided And Installed By Customer	
Item No.	Description
③	Meter Base
④	3" Rigid PVC Conduit
⑤	Sweep 3" sch. 40 PVC 36" radius
⑥	Conduit-3" Sch. 40 PVC
⑦	3" to 2-1/2" adapter for 200A meter base only refer to Q-1E standard
Provided And Installed By District	
Item No.	Description
△1	Conductors
△2	Meter



Notes:

- Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
- The District's service conductors will connect at the meter socket line terminals.
- Meter base must be installed, plumb and solid, and bonded to customer neutral per NEC, as required.
- For pre-approved meter bases and details, ref. District standards Q4-C through Q-4M.
- Reference District standards Q-7A and Q-7B for trenching details.
- 320A meter bases may only be utilized for single phase installations.
- Ringless meter bases will not be approved by the District.
- No conduit type fittings to be installed in conduit containing service conductors.



TITLE:

Service Entrance
Flush Mounted Underground
400 Amp or Less

DRAWN BY: JAD

DRAW DATE: 03/22/01

REV BY: TMG

REV DATE: 8/19/2020

REV NO: 3

DIR. ENG. JAS


SHT.

1 of 1

DATE: 9/21/20

DWG. NO.

Q-4B



Notes:


1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
3. For pre-approved meter bases, see document **Standard Q-4M**.
4. Ringless meter bases will not be approved by the District.
5. No conduit type fittings to be installed in conduit containing service conductors.
6. Meter base must have lugs which will accept #4/0 aluminum conductors.
7. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.



DRAWN BY: JAD
DRAW DATE: 07/10/03

TITLE: Underground Feed
200 Amp Meter Base
Single Phase 120/240 Volt
Residential

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/19/2020	
REV NO: 2	DIR. ENG. <i>JA</i> DATE: 9/11/20
DWG. NO.	Q-4C



Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
3. For pre-approved meter bases, see document **Standard Q-4M**.
4. Ringless meter bases will not be approved by the District.
5. No conduit type fittings to be installed in conduit containing service conductors.
6. Meter base must have lugs which will accept #4/0 aluminum conductors.
7. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.



DRAWN BY: JAD

DRAW DATE: 02/26/01

TITLE:

Underground Feed
200 Amp Meter Base
Network, 120/208 Volt
Residential

REV BY: TMG

SHT.

REV DATE: 8/19/2020

1 of 1

REV NO: 2


DIR. ENG.

DATE:

9/21/20

DWG. NO.

Q-4D



Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
3. For pre-approved meter bases, see document **Standard Q-4M**.
4. Ringless meter bases and safety socket by-passes will not be approved by the District.
5. No conduit type fittings to be installed in conduit containing service conductors.
6. Manual block type by-pass is required for 200A non-residential services.
7. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.



DRAWN BY: JAD

DRAW DATE: 02/26/01

TITLE:

Underground Feed
200 Amp Meter Base
Single Phase, 120/240 Volt
Non- Residential

REV BY: TMG

REV DATE: 8/19/2020

REV NO: 2

DIR. ENG. *[Signature]*

SHT.

1 of 1

DATE: 9/21/20

DWG. NO.

Q-4E

The fifth lug is required
in the 9 o'clock position
and bonded to the neutral

Block type by-pass stud
for by-pass clip
(TYP.)

Note 2

3" rigid conduit furnished
and installed
by the customer

Service conductor furnished and
installed by customer per NEC

Front View

3" Min. Knock-Out

Bottom View

Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
3. For pre-approved meter bases, see document **Standard Q-4M**.
4. Ringless meter bases and safety socket by-passes will not be approved by the District.
5. No conduit type fittings to be installed in conduit containing service conductors.
6. Manual block type by-pass is required for 200A non-residential services.
7. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.




TITLE:

Underground Feed
200 Amp Meter Base
Network, 120/208 Volt
Non - Residential

DRAWN BY: JAD

DRAW DATE: 02/26/01

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/19/2020	
REV NO: 2	DIR. ENG. <i>[Signature]</i> DATE: 7/21/20
DWG. NO.	
Q-4F	



Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
3. For pre-approved meter bases, see document **Standard Q-4M**.
4. All self-contained 320A services must use meter sockets rated for 320A continuous duty.
5. Ringless meter bases, and safety socket and lever by-passes will not be approved by the District.
6. No conduit type fittings to be installed in conduit containing service conductors.
7. Manual block type by-pass is required for 320A services.




DRAWN BY: JAD
DRAW DATE: 04/10/01

TITLE:

Underground Feed
320 Amp Meter Base
Single Phase, 120/240 Volt
Residential or Commercial

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/19/2020	
REV NO: 2	DIR. ENG. <i>[Signature]</i> DATE: 9/14/20
DWG. NO.	Q-4G



Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Meter base must be installed, plumb and solid, and bonded to customer neutral per the NEC, when required.
3. For pre-approved meter bases, see document **Standard Q-4M**.
4. Ringless meter bases and safety socket by-passes will not be approved by the District.
5. No conduit type fittings to be installed in conduit containing service conductors.
6. Manual block type by-pass is required for 200A non-residential services.
7. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.
8. Power conductor (high leg, color coded orange).



TITLE:

Underground Feed
200 Amp Meter Base
Three Phase
Non - Residential

DRAWN BY: JAD

DRAW DATE: 02/26/01

REV BY: TMG

REV DATE: 8/29/2020

REV NO: 2

DIR. ENG. *Sta*


SHT.

1 of 1

DATE: 7/21/20

DWG. NO.

Q-4H



Notes:

- Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
- Disconnect distance between manufactured (or mobile) homes must meet NEC requirements.
- Meter base pedestal must be installed in concrete to finished grade, plumb and solid, and bonded to customer neutral per NEC, as required.
- Reference District standards Q-7A and Q-7B for trenching details.
- Ringless meter bases will not be approved by the District.
- Meter base must have lugs which will accept #4/0 aluminum conductors.
- All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.
- No conduit type fittings to be installed in conduit containing service conductors.
- Multi-unit mobile home communities must have address identification permanently attached to the front of the meter base, per District standard Q-1C.
- Service conductor and conduit will be customer supplied and installed for services located within mobile home communities.



TITLE:

Underground Service
200 Amp
Metered Pedestal

DRAWN BY: JAD

DRAW DATE: 03/27/01

REV BY: TMG

REV DATE: 8/29/2020

REV NO: 1

DIR. ENG.


SHT.

1 of 1


DATE: 9/21/20

DWG. NO.


Q-4J



Detail A
Double back
uni-strut



Detail B
Double back
uni-strut



Front View

Side View

Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Disconnect distance between manufactured (or mobile) homes must meet NEC requirements.
3. Meter base vertical structural components must be adequately installed in concrete to finished grade, plumb and solid, and must also be bonded to customer neutral per NEC, as required.
4. Reference District standards Q-7A and Q-7B for trenching details.
5. Ringless meter bases will not be approved by the District.
6. All self-contained services, 200A and below, must use meter sockets rated for 200A continuous duty.
7. No conduit type fittings to be installed in conduit containing service conductors.
8. Multi-unit mobile home communities must have address identification permanently attached to the front of the meter base, per District standard Q-1C.
9. Service conductor and conduit will be customer supplied and installed for services located within mobile home communities.




TITLE:

200 Amp Component
Meter Pedestal
(Mounted on Uni-Strut)

DRAWN BY: SWT


DRAW DATE: 03/27/01

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/19/2020	
REV NO: 3	DIR. ENG. <i>[Signature]</i> DATE: 9/21/20
DWG. NO.	Q-4K



Detail A
Double back
uni-strut

Detail B
Double back
uni-strut



Front View

Side View

Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Meter base vertical structural components must be adequately installed in concrete to finished grade, plumb and solid, and must also be bonded to customer neutral per NEC, as required.
3. Reference District standards Q-7A and Q-7B for trenching details.
4. Ringless meter bases will not be approved by the District.
5. All self-contained 320A services must use meter sockets rated for 320A continuous duty.
6. No conduit type fittings to be installed in conduit containing service conductors.



TITLE:

320 Amp Component
Meter Pedestal
(Mounted on Uni-Strut)

DRAWN BY: DDB

DRAW DATE: 06/04/10

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/29/2020	
REV NO: 2	DIR. ENG. <i>[Signature]</i> DATE: 9/21/20
DWG. NO.	Q-4L

Q-3D

Overhead Feed 200A Single Phase, 120/240V (Residential)
B-Line 2M2R (OH) B-Line 204 MS68 (OH) Milbank U4517-DL-M4 (OH) Milbank U4518-XL-W (OH/UG) Milbank U5169-XTL-200 (OH/UG)

Q-3E

Overhead Feed 200A Network, 120/208V (Residential)
B-Line 204 MS68 w/50365 (5th Jaw Kit) (OH) Milbank U4517-DL-M4 w/K5T (5th Jaw Kit) (OH) Milbank U4518-XL-W w/K5T (5th Jaw Kit) (OH/UG)

Q-3F

Overhead Feed 200A Single Phase, 120/240V (Non-Residential)
B-Line U264 (OH/UG) Milbank U3514-XL (OH/UG)

Q-3G

Overhead Feed 200A Network, 120/208V (Non-Residential)
B-Line U264 w/50365 (5th Jaw Kit) (OH/UG) Milbank U3514-XL w/K5T (5th Jaw Kit) (OH/UG)

Q-3H

Overhead Feed 320A Single Phase, 120/240V (Residential/Commercial)
B-Line 324N (OH/UG) Milbank X3548-X (OH/UG) Siemens MM0404L1400SCS (OH/UG)

Q-3J

Overhead Feed 200A Three Phase (Non-Residential)
B-Line U267 (OH/UG) Milbank U3517-XL (OH/UG)

Q-4C

Underground Feed 200A Single Phase, 120/240V (Residential)
B-Line U2M2R (UG) B-Line U204 (UG) Milbank U4518-O-W (UG) Milbank U4518-XL-W (OH/UG) Milbank U5169-XTL-200 (OH/UG) Eaton MBER48B200BTS (UG)

Q-4D

Underground Feed 200A Network, 120/208V (Residential)
B-Line U204 w/50365 (5th Jaw Kit) (UG) Milbank U4518-O-W w/K5T (5th Jaw Kit) (UG) Milbank U4518-XL-W w/K5T (5th Jaw Kit) (OH/UG)

Q-4E

Underground Feed 200A Single Phase, 120/240V (Non-Residential)
B-Line U264 (OH/UG) Milbank U3514-XL (OH/UG)

Q-4F

Underground Feed 200A Network, 120/208V (Non-Residential)
B-Line U264 w/50365 (5th Jaw Kit) (OH/UG) Milbank U3514-XL w/K5T (5th Jaw Kit) (OH/UG)

Q-4G

Underground Feed 320A Single Phase, 120/240V (Residential/Commercial)
B-Line 324N (OH/UG), B-Line U4042MCC (UG) Milbank U3548-X (OH/UG) Milbank U3251-O-200-CB (UG) Milbank U6020-0-2/200 (UG) Siemens MM0404L1400SCS (OH/UG) Siemens MC0816B1400SCS (UG)

Q-4H

Underground Feed 200A Three Phase (Non-Residential)
B-Line U267 (OH/UG) Milbank 3517-XL (OH/UG) Milbank 127TB (UG)

Notes:

- Specifications for meter bases not listed may be submitted for review by the District.



TITLE:

Pre-Approved
Meter Bases

REV BY: MM	SHT. 1 of 1
REV DATE: 5/7/2025	
REV NO: 4	DIR. ENG. <i>SA</i> DATE: 5/19/25
DWG. NO.	


Q-4M

DRAWN BY: JWW
DRAW DATE: 10/01/13

CURRENT TRANSFORMERS

5/19/2025 3:09 PM F:\Apps\Eng\Engineering Drawings\Construction Standards Drawings\Construction Standards Folders Copyright © 2025 Public Utility District No. 1 of Benton County


	TITLE:	REV BY: MM		SHT.
	CURRENT TRANSFORMERS Q-5 Series	REV DATE: 05/19/25		1 of 1
		REV NO: 2	DIR. ENG.	DATE:
		DWG. NO. Q-5		
DRAWN BY: JAD				
DRAW DATE: 03/05/04				



Detail A
Double back
uni-strut



Detail B
Double back
uni-strut



Front View

Side View

Notes:

1. Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
2. Meter base vertical structural components must be adequately installed in concrete to finished grade.
3. Current transformer enclosure and mounting base to be supplied and installed by the customer.
4. Reference District standard Q-1B for conduit and conductor requirements.
5. Reference District standards Q-5B, Q-5E & Q-5F for current transformer enclosure specifications.
6. No conduit type fittings to be installed in conduit containing service conductors.

Copyright © 2020 Public Utility District No. 1 of Benton County

Benton PUD Construction Standards & Property Construction Standards




DRAWN BY: TKS
DRAW DATE: 8/20/2020

TITLE:

**Current Transformer Enclosure
(Mounted on Uni-Strut)**

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/29/2020	
REV NO: 0	DIR. ENG. DATE: 7/21/20
DWG. NO.	Q-5A



DRAWN BY: JAD
DRAW DATE: 03/07/01

TITLE:

Current Transformer (CT)
Enclosure Requirements for
Single Phase Services
400-800 Amps

REV BY: TMG	SHT.
REV DATE: 8/29/2020	1 of 2
REV NO: 2	DIR. ENG. <i>[Signature]</i> DATE: 9/21/20
DWG. NO.	Q-5B

Pre-Approved Single Phase Current Transformer Enclosure & Mounting Bases

CT Service Type		Cabinet Dimensions			CT Cabinets		CT Mounting Bases		
Service Size	Number of Load Conductors	Width	Height	Depth	Cooper B-Line Part #	Milbank Part #	Cooper B-Line Part #	Milbank Part #	EUSERC Drawing #
400A	1-2	24" min	48"	11"	244811 HRTCT or 304811 HRTCT	CT244811HC or CT304811HC	6019HA or 6019HAL	K4797 or K4903	328A or 328B
400-800A	1-4	36"	48"	11"	364811 HRTCT	CT364811HC	6019HE or 6019HEL	K4797 or K4729	

Notes:

- Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
- Current transformer enclosure and mounting base to be supplied and installed by the customer.
- Customer shall ensure the load conductors are compatible with the connectors on the EUSERC 328B style current transformer mounting base. All mechanical cable termination blocks shall be provided by the customer.
- Current transformers to be supplied and installed by District.
- The current transformer mounting base shall have a 50,000 Amp minimum fault current rating.
- The enclosure shall be raintight, with a sealable, hinged, cover.
- Reference District standard Q-1B for conduit and conductor requirements.
- Customer owned and installed service wires for single phase services are limited to (4) sets of conductors and shall not exceed 500 kcmil aluminum or copper.
- The customer shall make up and terminate the load side connections in the current transformer enclosure.
- The customer service entrance conduits must exit the enclosure on the load side of the current transformer mounting base. The District will not allow customer conductors or conduit in the District's terminating and pull space.
- A pre-wired meter base shall be provided by the District and installed by customer.
- Bonding must be in accordance with the current NEC requirements.
- Meter sockets shall be installed within 24" of non-hinge side of enclosure.
- If estimated load is over 50kVA and current transformer metering is needed to facilitate known additional load growth, customer may be allowed to install current transformer enclosure.
- Current transformer metering may be allowed within the secondary compartment of the transformer at the discretion of the District if circumstances are non-typical and minimum requirements are met.

Copyright © 2012 Public Utility District No. 1 of Benton County

Benton PUD Construction Standards & Property Construction Standards



TITLE:

Current Transformer (CT)
Enclosure Requirement for
Single Phase Services
201-800 Amps (Cont.)


DRAWN BY: JAD

DRAW DATE: 03/07/01

REV BY: TMG	SHT. 2 of 2
REV DATE: 8/21/2020	
REV NO: 2	DATE: 9/21/20
DWG. NO.	
Q-5B (Cont.)	

Copyright © 2018 Public Utility District No. 1 of Benton County

F:\Angel\Eng\Construction Standards Specifications & Property\Construction Standards



BENTON
PUD

DRAWN BY: JAD
DRAW DATE: 03/26/10

TITLE:

Current Transformer (CT)
Enclosure Requirements for
Three Phase Services
400-800 Amps

REV BY: TMG	SHT. 1 of 2
REV DATE: 8/29/2020	
REV NO: 3	DIR. ENG. 8/29/20
DWG. NO.	DATE: 9/21/20
Q-5E	

Pre-Approved Three Phase Current Transformer Cabinet & Mounting Bases

CT Service Type		Cabinet Dimensions			CT Cabinets		CT Mounting Bases		
Service Size	Number of Load Conductors	Width	Height	Depth	Cooper B-Line Part #	Milbank Part #	Cooper B-Line Part #	Milbank Part #	EUSERC Drawing #
400A	1-2	30"	48"	11"	304811HRTCT	CT304811-HC	6067HA or 6067HAL	K4798 or K4904	329A or 329B
400-800A	1-4	36"	48"	11"	364811HRTCT	CT364811-HC	6067HEE or 6067HEEL	K4798 or K4722	

Notes:

- Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
- Current transformer enclosure and mounting base to be supplied and installed by the customer.
- Customer shall ensure the load conductors are compatible with the connectors on the EUSERC 328B style current transformer mounting base. All mechanical cable termination blocks shall be provided by the customer.
- Current transformers to be supplied and installed by District.
- The current transformer mounting base shall have a 50,000 Amp minimum fault current rating.
- The enclosure shall be raintight, with a sealable, hinged, cover.
- Reference District standard Q-1B for conduit and conductor requirements.
- Customer owned and installed service wires for single phase services are limited to (6) sets of conductors and shall not exceed 750 kcmil aluminum or copper.
- The customer shall make up and terminate the load side connections in the current transformer enclosure.
- The customer service entrance conduits must exit the enclosure on the load side of the current transformer mounting base. The District will not allow customer conductors or conduit in the District's terminating and pull space.
- A pre-wired meter base shall be provided by the District and installed by customer.
- Bonding must be in accordance with the current NEC requirements.
- Meter sockets shall be installed within 24" of non-hinge side of enclosure.
- If estimated load is over 75kVA (120/208V) or 150kVA (277/480V) and current transformer metering is needed to facilitate known additional load growth, customer may be allowed to install current transformer enclosure.
- Current transformer metering may be allowed within the secondary compartment of the transformer at the discretion of the District if estimated load is at least 100kVA. Current transformer metering, specifically for services which are fed by a District 75kVA or smaller transformer shall be metered within a current transformer enclosure.

Copyright © 2018 Public Utility District No. 1 of Benton County

Benton PUD Construction Standards & Property Construction Standards



TITLE:


Current Transformer (CT)
Enclosure Requirement for
Three Phase Services
400- 800 Amps

DRAWN BY: JAD

DRAW DATE: 03/26/10

REV BY: TMG	SHT. 2 of 2
REV DATE: 8/29/2020	
REV NO: 3	DIR. ENG. <i>[Signature]</i> DATE: 9/21/20
DWG. NO.	

Q-5E (Cont.)



	TITLE: Current Transformer (CT) Enclosure Requirements for Commercial Three Phase Services 1200-2500 Amps	REV BY: TMG	SHT.
		REV DATE: 8/21/2020	1 of 2
		REV NO: 2	DATE: 9/21/20
		DWG. NO.	Q-5F

DRAWN BY: SWT
DRAW DATE: 05/12/10

Pre -Approved Three Phase Current Transformer Enclosure & Mounting Bases

CT Service Type		Cabinet Dimensions			CT Cabinets with Mounting Bases	
Service Size	Number of Load Conductors	Width	Height	Depth	Erickson Bulletin Numbers	Erickson Catalog Numbers
1200A	3	55"	64"	15"	BPCT-07A	CT-124-BP-SG
1600A	4	61"	64"	15"	BPCT-07A	CT-164-BP-SG
2000A	5	65"	64"	15"	BPCT-07A	CT-204-BP-SG**
2500A	7	65"	64"	15"	BPCT-07A	CT-254-BP-SG**

* INCLUDES SIDE GUTTER

** MUST CONTACT BENTON PUD PRIOR TO PURCHASE(NON-STANDARD)

Notes:

- Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
- Current transformer enclosure and mounting base to be supplied and installed by the customer.
- Customer shall ensure the load conductors are compatible with the connectors on the EUSERC 328B style current transformer mounting base. All mechanical cable termination blocks shall be provided by the customer.
- Current transformers to be supplied and installed by District.
- The current transformer mounting base shall have a 85,000 Amp minimum fault current rating.
- The enclosure shall be raintight, with a sealable, hinged, cover.
- Reference District standard Q-1B for conduit and conductor requirements.
- Customer owned and installed service wires for single phase services are limited to (6) sets of conductors and shall not exceed 750 kcmil aluminum or copper.
- The customer shall make up and terminate the load side connections in the current transformer enclosure.
- The customer service entrance conduits must exit the enclosure on the load side of the current transformer mounting base. The District will not allow customer conductors or conduit in the District's terminating and pull space.
- A pre-wired meter base shall be provided by the District and installed by customer.
- Bonding must be in accordance with the current NEC requirements.
- Meter sockets shall be installed within 24" of non-hinge side of enclosure.
- Customer will install bus bar and perch for window style current transformers.
- Current transformer metering may be allowed within the secondary compartment of the transformer at the discretion of the District if estimated load is at least 100kVA. Current transformer metering, specifically for services which are fed by a District 75kVA or smaller transformer shall be metered within a current transformer enclosure.

Copyright © 2012 Public Utility District No. 1 of Benton County

F:\Masters\Construction Standards Specifications & Property Construction Standards




DRAWN BY: SWT
DRAW DATE: 05/12/10

TITLE:

**Current Transformer (CT)
Enclosure Requirements for
Commercial Three Phase Services
1200-2500 Amps**

REV BY: TMG	SHT. 2 of 2
REV DATE: 8/21/2020	
REV NO: 2	DIR. ENG. <i>[Signature]</i> DATE: 7/21/20
DWG. NO.	Q-5F

**Notes:**

- Details shown are minimum District standards and are not intended to depict Washington State Labor and Industries requirements.
- Meter base vertical structural components must be adequately installed in concrete to finished grade.
- The District will provide a pre-wired meter base mounted on uni-strut to be installed by the customer.
- Refer to transformer pad details, District standards UG6-C, or UG6-C2.
- Refer to District standards Q-5B, Q-5E and Q-5F for current transformer requirements.
- Customer shall install 1" conduit from meter to secondary compartment of the transformer. Only with **PRIOR APPROVAL**, may conduit run up to 25' in length and/or exceed (4) total bends totaling 360 degrees.
- No conduit type fittings to be installed in conduit containing service conductors or low voltage wires.
- Current transformer metering may be allowed within the secondary compartment of the transformer at the discretion of the District



TITLE:

**Self Supported CT Meter Pedestal
with CT's Installed in Secondary Compartment
of District Transformer**

REV BY: MM

SHT.

REV DATE: 5/1/2025

1 of 1

REV NO: 5

DIR

ENG

DATE:


5/19/25

DWG. NO.

Q-5G

DRAWN BY: JAD

DRAW DATE: 03/27/01



Notes:

1. Contact Engineering regarding all switchgear installations for prior approval.
2. Busways must remain in position when the removable bus link "B" is removed.
3. Set the direction of feed from the top. No other customer conductors shall pass through this compartment.
4. Bus clearance dimension measured to inside edge of the compartment access opening.
5. Reference EUSERC 320 and 322.
6. Customer to install and terminate all conductors.
7. Current transformers to be supplied and wired by the District.
8. Customer shall remove bus links to facilitate CT installation and shall re-torque following completion.



DRAWN BY: SWT
DRAW DATE: 06/04/10

TITLE:

Current Transformer Compartment for Switch Gear/Switch Board 400-3000 Amps

REV BY: TMA	SHT.
REV DATE: 03/19/2018	1 of 1
REV NO: 2	DIR. ENG. <i>FD</i> DATE: <i>3/18</i>
DWG. NO.	Q-5H

TRANSFORMER PADS AND CLEARANCES

6/12/2025 7:57 AM F:\Apps\Eng\Engineering Drawings\Construction Standards Drawings\Construction Standards Folders Copyright © 2025 Public Utility District No. 1 of Benton County




DRAWN BY: JAD
DRAW DATE: 03/05/04

TITLE:

TRANSFORMER PADS
& CLEARANCES
Q-6 Series
UG6 Series

REV BY: MM		SHT. 1 of 1
REV DATE: 05/19/25		
REV NO: 2	DIR. ENG.	DATE:
DWG. NO. Q-6 UG6		



Notes:

1. All dimensions are minimum.
2. No obstructions are allowed over transformer.
3. Landscaping must maintain a 12' clearance from the front and a 3' clearance from all other sides. The District shall not be responsible for damages to landscaping violating the minimum clearance requirements.
4. Installation must not violate WAC-296-46B-450 transformers.




DRAWN BY: JAD
DRAW DATE: 03/27/01

TITLE:

Installation Clearances for Commercial and Residential Transformers

REV BY: TMG	SHT. 1 of 1
REV DATE: 8/21/2020	
REV NO: 2	DIR. ENG. <i>[Signature]</i> DATE: 9/21/20
DWG. NO.	Q-6C



UG6-C (500 kVA and Smaller):
Customer to install 3 - 6" Sch 40
PVC conduits and 36" sweeps.

UG6-C2 (750kVA and Larger):
Customer to install 6 - 6" Sch 40
PVC conduits and 36" sweeps.

Plan

NOTE:

Install pedestal to
avoid interference
when transformer
door is open.

Notes:

1. Secondary termination cabinet shall be installed within 10' of transformer pad and be lockable.
2. Terminations of customer owned wire in secondary cabinet will be made by the customer.
3. Reference transformer pad details, District standard UG6-C or UG6-C2.
4. Reference CT meter base construction, District standard Q-5G.
5. Primary cable area conduit and ground wire will be District supplied and customer installed.
6. When required by the District current transformers may be installed in the secondary compartment of transformer.
7. Termination cabinet grounds shall be bonded with transformer pad grounds.
8. Termination cabinet specifications shall be submitted to the District for approval prior to installation.
9. Coordinate termination cabinet location with District.



TITLE:

600V Termination Cabinet Guideline

DRAWN BY: SWT

DRAW DATE: 06/21/10

REV BY: MM

REV DATE: 5/01/25

REV NO: 2

DIR. ENG. *JS*

SHT.

1 of 1

DATE: 5/27/25


DWG. NO.

Q-6G


(2) Ground rods required;
District supplied
Customer Installed
(See Note 5 & 9)

#4 Copper Ground loop
District Supplied
Customer Installed
(See Note 5)

(Secondary cable area)
Conduit and wire;
Customer Supplied & Installed
(See Note 10 for wire and CT install)



Plan View
Concrete Transformer
Pad by Customer



Section A-A



TITLE:

Transformer Pad Details
500 kVA & Below
Three Phase Pad

DRAWN BY: JAD

DRAW DATE: 11/01/01

REV BY: MM	SHT. 1 of 2
REV DATE: 3/12/25	
REV NO: 3	DIR. ENG. <i>[Signature]</i> DATE: 5/20/25
DWG. NO.	

UG6-C

UG6-C			
Item	Item Code	Description	Qty.
1	327100	Clamp, Ground Rod 5/8	2
2	337381	Ground Rods 5/8 X 8 FT	2
3	400300	Wire, Copper, #4-7, Hard Drawn Strand	50'
4	633651	Bend 90 PVC S/80 4in 36R	1

Notes:

- Ground under pad shall be 95% minimum compaction.
- Concrete shall be Portland Cement concrete, 5 sack mix, attaining 3000 P.S.I. at 28 days.
- Top of pad shall be level and finished smooth. Surface shall not contain honeycomb or segregation.
- Barricade traffic bollards provided and installed by customer - contact District engineering to determine location of posts. When required, bollards shall not interfere with swing of transformer doors.
- Customer to pick up 4" primary conduit sweep, 2 ground rods, and #4 Str. bare CU. ground wire from the District warehouse located at 1500 S. Ely street, Kennewick.
- Maximum number of 6 conductors per phase of 750 kcmil. Contact the District if additional conductors per phase will be required.
- For pad location, reference District standard Q-6C for clearance to existing structures.
- For pads located near regulated bodies of water contact the District for an alternative design with oil containment provisions.
- Exterior ground rod shall be driven flush with grade or in such a manner that eliminates possible tripping hazards and allows for future inspection with minimal effort. Interior ground rod shall be driven such that no more than 4" extends above grade.
- District personnel may be required to assist in pulling conductor into transformer compartment. District personnel will make all transformer terminations. Current transformer installation and wiring shall be completed by District personnel when required.
- Transformer pad shall be placed on bedding material which shall be minimum 3 inches in depth with 5/8" - 7/8" gravel or undisturbed ground.





TITLE:

Transformer Pad Details
500 kVA & Below
Three Phase Pad

DRAWN BY: JAD
DRAW DATE: 11/01/01

REV BY: MM	SHT. 2 of 2
REV DATE: 3/12/25	
REV NO: 3	DIR. ENG. DATE: 5/20/25
DWG. NO. UG6-C	



TITLE:

**Transformer Pad
750 kVA & Above
Three Phase Pad Details**

DRAWN BY: JAD

DRAW DATE: 11/01/01

REV BY: MM	SHT. 1 of 2
REV DATE: 3/12/25	
REV NO: 3	DATE: 5/20/25
DIR. ENG. <i>JA</i>	
DWG. NO.	

UG6-C2

UG6-C2			
Item	Item Code	Description	Qty.
1	327100	Clamp, Ground Rod 5/8	2
2	337381	Ground Rods 5/8 X 8 FT	2
3	400300	Wire, Copper, #4-7, Hard Drawn Strand	50'
4	633651	Bend 90 PVC S/80 4in 36R	1

Notes:

1. Ground under pad shall be 95% minimum compaction.
2. Concrete shall be Portland Cement concrete, 5 sack mix, attaining 3000 P.S.I. at 28 days.
3. Top of pad shall be level and finished smooth. Surface shall not contain honeycomb or segregation.
4. Barricade traffic bollards provided and installed by customer - contact District engineering to determine location of posts. When required, bollards shall not interfere with swing of transformer doors.
5. Customer to pick up 4" primary conduit sweep, 2 ground rods, and #4 Str. bare CU. ground wire from the District warehouse located at 1500 S. Ely street, Kennewick.
6. Maximum number of 6 conductors per phase of 750 kcmil. Contact the District if additional conductors per phase will be required.
7. For pad location, reference District standard Q-6C for clearance to existing structures.
8. For pads located near regulated bodies of water contact the District for an alternative design with oil containment provisions.
9. Exterior ground rod shall be driven flush with grade or in such a manner that eliminates possible tripping hazards and allows for future inspection with minimal effort. Interior ground rod shall be driven such that no more than 4" extends above grade.
10. District personnel may be required to assist in pulling conductor into transformer compartment. and will make all transformer terminations.
11. Current transformer installation and wiring to be completed by District personnel when required.
12. Transformer pad shall be laid on bedding material which shall be minimum 3" in depth with 5/8" - 7/8" gravel or undisturbed ground.



TITLE:

Transformer Pad
750 kVA & Below
Three Phase Pad Details

DRAWN BY: JAD

DRAW DATE: 11/01/01

REV BY: MM

REV DATE: 3/12/25

REV NO: 3

DIR. ENG. *JA*



SHT.

2 of 2

DATE: 5/20/25

DWG. NO.

UG6-C2



NOTE:
CLEARANCE TO STRUCTURE REF. STD. Z-6C

SECTION A-A



TITLE:

**Pre-Cast Transformer Pad
for 500 kVA and Below Three Phase**

DRAWN BY: JAD

DRAW DATE: 11/01/01

REV BY: MM	SHT. 1 of 2
REV DATE: 05/19/25	
REV NO: 1	DIR. ENG. <i>[Signature]</i> DATE: 5/27/25
DWG. NO.	

UG6-C3

UG6-C3

Item	Item Code	Description	Qty.
1	337381	Ground, Rod, 5/8x8 8 ft	2
2	633651	Bend PVC 90 Sch 80 4in 36R	1
3	400300	Wire, Copper, #4-7, Hard Drawn Strand	50'
4	327100	Clamp, Ground Rod 5/8	2
5	690600	Transformer Pad 3PH 500 kVA & Under	1

Notes:

- Transformer pad shall be placed on bedding material which shall be a minimum of 3 inches in depth with 5/8" - 7/8" gravel or undisturbed ground.
- Barricade Posts by Customer - Contact engineering to determine location of posts when required. (Posts must not interfere with the swing of the transformer doors.)



TITLE:

Pre-Cast Transformer Pad
for 500 kVA and Below Three Phase

DRAWN BY: JAD

DRAW DATE: 11/01/01

REV BY: MM	SHT. 2 of 2
REV DATE: 5/19/25	
REV NO: 1	DIR. <i>[Signature]</i> DATE: 5/27/25
DWG. NO.	
UG6-C3	

TRENCHING

5/19/2025 3:17 PM F:\Apps\Eng\Engineering Drawings\Construction Standards Drawings\Construction Standards Folders Copyright © 2025 Public Utility District No. 1 of Benton County




DRAWN BY: JAD
DRAW DATE: 03/05/04

TITLE:

TRENCHING
Q-7 Series

REV BY: MM	SHT.
REV DATE: 05/19/25	1 of 1
REV NO: 2	DATE:
DIR. ENG.	
DWG. NO.	
Q-7	



Notes:

1. Details shown are minimum District specifications and are not intended to depict Washington State Labor and Industries requirements.
2. Conduit may not exceed maximum allowable length, or have bends exceeding 270 degrees including sweeps at the meter base and transformer or pole.
3. Trenches are subject to inspection by the District and must obtain minimum standards prior to backfill.
4. Open conduit shall be capped or sealed in a manner to prevent dirt from entering.
5. Contact 811 to request utility locates two days prior to digging.
6. 12" horizontal and 3" vertical crossing (using compacted dirt) separation required between power and all other utilities,



TITLE:

Trenching & Conduit Details for Typical Underground Service Installation from Pad Mount Transformer

DRAWN BY: JAD

DRAW DATE: 3/27/01

REV BY: MM

REV DATE: 5/1/2025

REV NO: 4

DIR:

ENG:

SHT.

1 of 1


DATE:

5/27/25

DWG. NO.

Q-7A

4/29/2025 1:14 PM F:\apps\Eng\Engineering Drawings\Construction Standards Drawings\Folders\Standards - CAD Files\Q - Standards Copyright © 2025 Public Utility District No. 1 of Benton County



Notes:

1. Details shown are minimum District specifications and are not intended to depict Washington State Labor and Industries requirements.
2. Conduit may not exceed maximum allowable length, or have bends exceeding 270 degrees including sweeps at the meter base and transformer or pole.
3. Trenches are subject to inspection by the District and must obtain minimum standards prior to backfill.
4. Open conduit shall be capped or sealed in a manner to prevent dirt from entering.
5. Contact 811 to request utility locates two days prior to digging.
6. 12" horizontal and 3" vertical crossing (using compacted dirt) separation required between Power and all other utilities,



TITLE:

**Trenching & Conduit Details
for Typical Underground, Service Installation
from Overhead Transformer**

DRAWN BY: JAD

DRAW DATE: 03/27/01

REV BY: MM

REV DATE: 3/13/25

REV NO: 3

DIR. ENG.

DATE: 5/19/25

DWG. NO.

Q-7B

SHT.

1 of 1

NET METERING SERVICES

5/19/2025 3:22 PM F:\Apps\Eng\Engineering Drawings\Construction Standards Drawings\Construction Standards Folders Copyright © 2025 Public Utility District No. 1 of Benton County




DRAWN BY: DDB
DRAW DATE: 03/22/12

TITLE:

NET METERING SERVICES
Q-8 Series

REV BY: MM		SHT. 1 of 1
REV DATE: 10/01/2013		
REV NO: 2	DIR. ENG.	DATE:
DWG. NO. Q-8		



Notes:

Connecting customer generation equipment to the Benton PUD (BPUD) distribution system requires completion of a Net Metering Application and signing of a Net Metering Interconnection Agreement.

1. This standard represents a typical arrangement for a net metering installation, if battery backup is being provided reference Q-8B. The details shown are not intended to depict Washington State Department of Labor and Industries (L&I) requirements. L&I approval of installation is required prior to customer receiving approval from BPUD for final interconnection of generator to the BPUD distribution system. Customer shall provide BPUD with a copy of the documentation of L&I approval.
2. Customer's must provide a one-line electrical schematic drawing to BPUD which is specific to the proposed installation.
3. Customer shall install a readily accessible utility disconnecting means (sized and UL listed for the application) for customer generation equipment. Disconnecting means shall be located adjacent to the production meter as shown.
4. Upon receiving L&I approval, BPUD will complete a field inspection of the customer's net metering installation. Approved installations will be documented by BPUD's completion of a Generating Facility Certificate of Completion. This certificate represents the customer's authorization to energize their generation equipment and interconnect their net metering installation to the BPUD distribution system.
5. AC production meter base shall be labeled, "CUSTOMER GENERATOR, PRODUCTION METER", with engraved phenolic placards; 3/8" white capitalized lettering on a red background.
6. Main electric service (Net Meter) meter base shall be labeled "NET METER, CUSTOMER GENERATOR CONNECTED TO THIS SERVICE", with engraved phenolic placards; 3/8" white capitalized lettering on a red background.
7. When the production meter is not within line of sight of the net meter, an engraved placard showing both meter locations shall be installed next to the Production and Net meterbases.
8. If customer's existing meterbase is "Banjo Style", it shall be upgraded to current BPUD standards. Reference Q3 or Q4, whichever applies, for meterbase specifications.
9. Loadside source connections allowed per NEC 705.12 shall not be permitted within Benton PUD controlled self-contained meter enclosures.
10. Production meter base shall not be affixed to manufactured home or any temporary structure. See Q-1F for additional requirements.
11. If multiple arrays/inverter circuits are utilized a combiner panel shall be provided that connects to a single production meter.
12. Refer to BPUD Standard, Q1-F, for meter base clearances.

REV BY: MM	SHT. 1 of 1
REV DATE: 5/5/25	
REV NO: 5	DIR. ENG. 8/15
DWG. NO. Q-8A	DATE: 5/19/25




TITLE:

Customer Generator Net Metering Installation (No Battery Backup)

DRAWN BY: SWT

DRAW DATE: 06/02/10



Notes:

1. Connecting customer generation equipment to the Benton PUD (BPUD) distribution system requires completion of a Net Metering Application and signing of a Net Metering Interconnection Agreement.
2. This standard represents a typical arrangement for a net metering installation with Battery backed up loads. The details shown are not intended to depict Washington State Department of Labor and Industries (L&I) requirements. L&I approval of installation is required prior to customer receiving approval from BPUD for final interconnection of generator to the BPUD distribution system. Customer shall provide BPUD with a copy of the documentation of L&I approval.
3. Customer's must provide a one-line electrical schematic drawing to BPUD which is specific to the proposed installation.
4. Customer shall install a readily accessible utility disconnecting means (sized and UL listed for the application) for customer generation equipment. Disconnecting means shall be located adjacent to the production meter as shown.
5. Upon receiving L&I approval, BPUD will complete a field inspection of the customer's net metering installation. Approved installations will be documented by BPUD's completion of a Generating Facility Certificate of Completion. This certificate represents the customer's authorization to energize their generation equipment and interconnect their net metering installation to the BPUD distribution system.
6. AC production meter base shall be labeled, "CUSTOMER GENERATOR, PRODUCTION METER", with engraved phenolic placards; 3/8" white capitalized lettering on a red background.
7. Main electric service (Net Meter) meter base shall be labeled "NET METER, CUSTOMER GENERATOR CONNECTED TO THIS SERVICE", with engraved phenolic placards; 3/8" white capitalized lettering on a red background.
8. When the production meter is not within line of sight of the net meter, an engraved placard showing both meter locations shall be installed next to the Production and Net meterbases.
9. If customer's existing meterbase is "Banjo Style", it shall be upgraded to current BPUD standards. Reference Q3 or Q4, whichever applies, for meterbase specifications.
10. Loadside source connections allowed per NEC 705.12 shall not be permitted within Benton PUD controlled self-contained meter enclosures.
11. Production meter base shall not be affixed to manufactured home or any temporary structure. See Q-1F for additional requirements
12. If multiple arrays/inverter circuits are utilized a combiner panel shall be utilized with a single production meter.
12. If multiple arrays/inverter circuits are utilized a combiner panel shall be provided that connects to a single production meter.
13. Transfer switch shall be an open transition "break before make" style and is required to be submitted for approval.
14. Refer to BPUD Standard, Q1-F, for meter base clearances.



TITLE:

Customer Generator Net Metering Installation (Battery Backup)

REV BY: MM	SHT. 1 of 1
REV DATE: 5/05/25	
REV NO: 0	DIR. ENG. DATE: 5/12/25
DWG. NO.	
Q-8B	

DRAWN BY: DAB
DRAW DATE: 4/17/25

FIBER SERVICES

5/19/2025 3:26 PM F:\Apps\Eng\Engineering Drawings\Construction Standards Drawings\Construction Standards Folders Copyright © 2025 Public Utility District No. 1 of Benton County




TITLE:

FIBER SERVICES
Q-9 Series

REV BY: MM		SHT. 1 of 1
REV DATE: 05/19/25		
REV NO: 2	DIR. ENG.	DATE:
DWG. NO. Q-9		

DRAWN BY: DDB
DRAW DATE: 03/22/12



Notes:

1. All dimensions are minimum.
2. No obstructions are allowed over transformer or fiber hand hole.
3. Refer to District planting guide for landscaping.



DRAWN BY: RPR
DRAW DATE: 07/02/07

TITLE:

Installation Practices for
Customer Fiber Services

REV BY: JWV	SHT. 1 of 1
REV DATE: 10/01/2013	
REV NO. 1	DIR. ENG. DATE: 4/14
DWG. NO.	

Q-9A

WORK AREA CLEARANCES

5/19/2025 3:30 PM F:\Apps\Eng\Engineering Drawings\Construction Standards Drawings\Construction Standards Folders Copyright © 2025 Public Utility District No. 1 of Benton County





DRAWN BY: DDB
DRAW DATE: 03/22/12

TITLE:

WORK AREA CLEARANCES
Q-10 Series

REV BY: MM		SHT. 1 of 1
REV DATE: 05/19/25		
REV NO: 2	DIR. ENG.	DATE:
DWG. NO. Q-10		




DRAWN BY: DDB
DRAW DATE: 11/03/10

TITLE:

**Work Area Clearance
Utility Poles and Junction Boxes**

REV BY: TMG	SHT. 1 of 1
REV DATE: 9/12/2020	
REV NO: 2	DIR. ENG. <i>[Signature]</i> DATE: 9/21/20
DWG. NO.	Q-10A



Typical Pedestal

Note:

1. Vegetation in work area shall be less than 3" above final grade.



TITLE:

Work Area Clearance
Pedestals

DRAWN BY: DF

DRAW DATE: 6/09/2025

REV BY: N/A		SHT. 1 of 1	
REV DATE: N/A			
REV NO: 0	DIR. ENG. <i>[Signature]</i>	DATE: 6/11/25	
DWG. NO. Q-10B			

